RI WAP BOILER REPLACEMENT PROGRAM BOILER PUNCH LIST FOR NEW INSTALLATIONS

- 1. New oil line
- 2. New feed valve unless waived by OER
- 3. New X-Trol tank (or equivalent)
- 4. New smoke pipe with barometric damper screwed together
- 5. New low water cut off
- 6. Chimney base MUST be cleaned
- 7. Remote switch (stairway switch) and Firematic
- 8. All radiator and main vents MUST be replaced (steam systems)
- 9. All air vents must be replaced (hydronic systems)
- 10. All packing nuts must be leak-free (to include radiators)
- 11. New thermostat (main zone only)
- 12. Mobile home stack pipes must not have any elbows. Vent pipe must be stainless steel or a sweep pipe per manufacturer
- 13. Mobile home furnace bases MUST be replaced unless waived in writing by OER
- 14. All units with tankless heaters MUST have automatic tempering valve
- 15. Hydronic boilers must have backflow preventer
- 16. Circulator pumps must be replaced
- 17. Units must be installed on minimum 2" block
- 18. Units must be Energy Star rated unless waived in writing by OER
- 19. Efficiency test MUST be done and a copy left on site, and one forwarded with invoice
- 20. A copy of the permit with the final inspection must be included with the invoice
- 21. Piping on steam must be covered from unit to header (FOAM PIPE WRAP IS NOT ACCEPTABLE)
- 22. All hydronic systems must have a shut off valve on supply and return (HOT WATER BOILERS, NOT APPLICABLE TO STEAM)
- 23. Agencies ARE NOT checking for code that is the responsibility of the local inspector
- 24. All new installs must be done during normal working hours (8 A.M. to 6 P.M.) unless waived in writing from OER
- 25. All sub-contractors must be registered with OER and on the OER Contractor List
- 26. Bids must include the make, model and serial number of the old unit; and the make, model and serial number of the new unit
- 27. License number must appear on bid and on invoice per State Department of Professional Regulation
- 28. Contractor must leave client with a 24-hour number for emergency service